

Ladder Inspection Form

<u>ITEMS TO BE INSPECTED</u>	<u>Needs Repair</u>	<u>OK</u>
Loose steps or rungs (consider loose if they can be moved by hand)		
Loose nails, screws, bolts, or other metal parts.		
Cracked, split, or broken uprights, braces, steps or rungs.		
Slivers on uprights, rungs, or steps.		
Damaged or worn on non-skid base.		
Rusted or corroded spots.		
Stepladders	Needs Repair	OK
Wobbly (from side strain).		
Loose or bent hinge spreaders.		
Stop on hinge spreaders broken.		
Broke, split, or worn steps.		
Loose hinges.		
Extension Ladders	Needs Repair	OK
Loose broken or missing extension locks.		
Defective Locks that do not seat properly when the ladder is extended.		
Deterioration of the rope, from exposure to acid and other destructive agents.		
Trolley Ladders	Needs Repair	OK
Worn or missing tires.		
Wheels that bind.		
Floor wheel brackets missing.		
Ladders binding in guides.		
Ladder and stop rails broken, loose, or missing.		
Rail supports broken or section of rail missing		
Trolley wheels out of adjustment.		
Trestle Ladders	Needs Repair	OK
Loose hinges.		
Wobbly.		
Loose or bent hinge spreaders.		
Stop on hinge spreader broken.		

Centre section guide for extension out of alignment.		
Defective locks for extension.		
Section Ladders	Needs Repair	OK
Worn or loose metal parts.		
Wobbly.		
Loose or bent hinge.		
Fixed Ladder	Needs Repair	OK
Loose, worn, or damaged rungs or side rails.		
Damaged or corroded parts of the cage.		
Corroded bolts and rivet heads on the inside of metal stocks.		
Weakened or damaged rungs on the brick or concrete slabs.		
Damaged or corroded handrails or brackets in the platforms.		
Fire Ladders	Needs Repair	OK
Markings illegible.		
Improperly stored.		
Storage Obstructed.		